

GENEVA FIRE DEPARTMENT
HAZARD WARNING NOTICE

Fire Prevention
Phone: (440) 466-3321

Date _____

Inspector _____

Compliance Date FORTHWITH

Will Re-inspect on or About _____

Business Address _____

Business Name _____

Business Owner _____

Building Owner _____

Business Phone _____

Owner's Phone _____

FIRE PROTECTION

- ___ Fire Sprinkler System Out of Date (Annual Test)
- ___ Fire Alarm System Out of Date
- ___ Fire Extinguishers Out of Date (Annual Service)
- ___ Hood System Out of Service (Requires 6 Month Service)
- ___ Obstructed Sprinkler Heads (Required 18 Inches Minimum Clearance)
- ___ Fire Doors Blocked, Obstructed, Not Operational
- ___ Rolling Fire Doors/Shutter (Annual Testing Required)
- ___ Lack of Fire Extinguishers ___ Need, Minimum Rating _____
- ___ Other _____

EXITS

- ___ Exit Door Blocked, Obstructed
- ___ Exit Aisle Blocked, Obstructed
- ___ Exit Signs Not Illuminated
- ___ Repair Battery Back-up for Exit Signs
- ___ Improper Locks on Egress Doors (Slide Bolts, Hasps, Padlock, Keyed Deadbolt, Others)
- ___ Additional Illuminated Exit Signs Needed
- ___ All Exit Signs to be Equipped with Battery Back-up or "Self-Luminous"
- ___ Other _____
- ___ Exit Door Locked
- ___ Emergency Lights Required
- ___ Emergency Lights Not Operational

ELECTRICAL

- ___ Exposed, Broken, Outlet Plated, Switches
- ___ Exposed, Bare Wiring
- ___ Storage Too Close to Electrical Panels (30 Inch Clearance Required)
- ___ Improper Extension Cords (Only Circuit Breaker Type Cords Permitted)
- ___ Other _____

MISCELLANEOUS

- ___ Compressed Gas Cylinders Unsecured
- ___ Accumulation of Rubbish
- ___ Storage Too Close to Ceiling
- ___ Address Improperly Posted
- ___ Open Burning Prohibited
- ___ Fire Lane Needs Posted
- ___ Combustibles Too Close to Heat
- ___ Improper Storage of Flammable Liquids
- ___ Improper Use of Flammable Liquids
- ___ Other _____

COMMENTS

Received By: _____